

SIOUX CITY PRETREATMENT PROGRAM INDUSTRY SELF MONITORING REPORT



Month

Industry Name

Industry Permit Number

Day of Month	Totalized Flow	Daily Flow	pH	pH	Sampler	Notes/Deficiencies (Plant details that may effect flow, pH, sampler temp or sample)
	Units (MG or gal) Record Daily	Units (MGD or gpd) Record Daily	S.U.s Per Permit	Temp (°C) Per Permit	Temp (°C) Record Daily	
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
AVERAGE		NA			NA	
MAX		0			0	

Note 1: pH of the discharge shall be between 5 and 11.5 S.U.s at all times per 40 CFR 403.5(b)(2).

Note 2: Sampler Temperature must be maintained between 2 and 6 degrees Celcius at all times. Any excursions require notification to the City within 24 hours of becoming aware and alternative measures to maintain temperature must be made (e.a.. supplement with ice).

Certification Waiver:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signed by an Authorized Representative¹:

1 Refer to 40 CFR 403.12(l) for the signatory requirements

_____ **Date**